


### CONDUIT WIRING SCHEDULE

RUN	CONDUIT SIZE	ILLUM.	GROUND	SERVICE	NOTES
△					
1	2-1/2" RMC			3 #000 AWG	OVERHEAD
2	2-1/2" PVC			3 #000 AWG	UNDERGROUND
3	3/4" PVC		1 #4		
4	2" PVC	2 #8 3 #12	1 #8		#12 TO PHOTOCCEL
5	1 1/2" PVC	2 #8 3 #12	1 #8		#12 TO PHOTOCCEL
6	1 1/2" PVC	2 #8	1 #8		

Conduit & Conductor sizes are typical and may need to be adjusted for voltage drop.  
 Note: All Conductors shall be copper.

	<p style="font-size: 1.2em; font-weight: bold; margin: 0;">City of Bremerton</p> <hr style="border: 1px solid black; margin: 5px 0;"/> <p style="font-weight: bold; margin: 0;">PUBLIC WORKS</p> <hr style="border: 1px solid black; margin: 5px 0;"/> <p style="font-weight: bold; margin: 0;">ENGINEERING DIVISION</p>	<p style="font-size: 1.2em; font-weight: bold; margin: 0;">TYPICAL CONDUIT RISER</p> <p style="font-size: 0.8em; margin-top: 10px;">Alteration of this drawing is prohibited. Any approval of an altered drawing is unauthorized and void.</p>	<div style="border: 1px solid black; padding: 5px; font-size: 1.2em; font-weight: bold; margin: 0;">7018</div> <div style="border: 1px solid black; padding: 5px; font-size: 0.8em; margin-top: 5px;">Revision Date 8/22/08</div>
--	--	--	---